

## PORTABLE APPLIANCE TESTING REPORT

<h3 style="margin: 0;">Dynamic Electrical Systems</h3> <p style="margin: 0;">83 Huntingdale Green Ballyclare Co. Antrim BT39 9FL Phone: 07814788883 / 07763754317    Email: info@dynamicelectricalsystems.co.uk</p>	REPORT NO.:	147	Chris Armstrong 10 Seskin Road Straird
	DATE:	7/7/21	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	PASS or FAIL	COMMENTS
					EARTH	INSULATION			
					Ohms	Mohms			
1	Extension Lead	Mobile trailer	E12	✓	0.09	> 999	✓	P	
2	Sound desk	"	SC1	✓	0.07	> 999	✓	P	
3	wireless mic	"	SC2	✓	—	> 999	✓	P	
4	FX shot	"	SC1	✓	0.14	> 99.9	✓	P	
5	vBar Pak	"	SC1	✓	0.11	> 99.9	✓	P	
6	TP Link	"	SC2	✓	—	> 999	✓	P	
7	Mega QA LT	"	SC2	✓	—	> 999	✓	P	
8	Mega QA LT	"	SC2	✓	—	> 999	✓	P	
9	Mega QA LT	"	SC2	✓	—	> 999	✓	P	
10	Mega QA LT	"	SC2	✓	—	> 999	✓	P	
11	Mega Tripar P.P	"	SC2	✓	—	> 999	✓	P	
12	Mega Tripar P.P	"	SC2	✓	—	> 999	✓	P	
13	Mega Tripar P.P	"	SC2	✓	—	> 99.9	✓	P	
14	Mega Tripar P.P	"	SC2	✓	—	> 999	✓	P	
15	Stinger II	"	SC1	✓	0.09	> 999	✓	P	
16	Swarm FFX	"	SC1	✓	0.10	> 999	✓	P	
17	Mini LED SPOT	"	SC2	✓	—	> 999	✓	P	
18	Mini LED SPOT	"	SC2	✓	—	> 999	✓	P	



